



NOZZLE SCHEDULE

ITEM	SIZE	RATING	TYPE	MATL	REMARKS	NOTES
A	3"	N.P.T.	W.F.	C.S.	PRIMARY	EMERGENCY VENT OPENING
B	3"	N.P.T.	H.CPL.	C.S.	SECONDARY	EMERGENCY VENT OPENING
C	2"	N.P.T.	CPL.	C.S.		INTERSTICE MONITORING PORT
D	2"	N.P.T.	W.F.	C.S.		



LEFT SIDE



FRONT VIEW

NOTES:

- A. Material: H.R. Carbon Steel.
- B. Design Pressure: Atmospheric.
- C. Design Temperature: Ambient.
- D. Built & Labeled per U.L. Spec. #142.
- E. Air Test with Water & Soap Suds Solution.
- F. Interior: Remove Weld Slag (Ship Clean & Dry).
- G. Exterior: Gray primer included; see Sales Order for top coat.
- H. All Fittings to be Protected for Shipment.
- I. Customer to verify nozzle locations, sizes, and quantities.
- J. Saddles/skids may require shimming or grouting during installation.

<p style="text-align: center; font-size: small;">APPROVAL FOR CONSTRUCTION SCHEDULE A - MASTER TERMS & CONDITION OF SALE*</p> <p><input type="checkbox"/> APPROVED AS DRAWN.</p> <p><input type="checkbox"/> APPROVED WITH NOTED CHANGES. CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND CONFIRMED ORDER ARE RECEIVED.</p> <p>SIGNATURE: _____</p> <p>DATE: _____</p>	<p>SALES ORDER:</p> <p style="text-align: center;">ONE CLARION</p> <p style="text-align: center;">www.clarionmunicipal.com</p>	<p>WEIGHT (LBS): 600</p> <p style="text-align: right; font-size: x-small;">All units inches unless stated otherwise</p> <p>DESCRIPTION: 150 GALLON 30" I.D. x 4'-0" O.A.L. DOUBLE WALL SKID TANK</p> <p>CUSTOMER: _____ P.O.# _____</p> <p>DATE: 06/07/23 SCALE: _____ DWG.# NB00150DWS03012G DRAWN BY: WR</p> <p style="text-align: right;">SHEET 1 OF 1</p>
---	--	--